

CITY OF ARLINGTON
STORM DRAINAGE NOTES:

1. ALL STORM DRAINAGE IMPROVEMENTS SHALL BE CONSTRUCTED IN ACCORDANCE WITH THESE APPROVED PLANS AND CITY STANDARDS AND SPECIFICATIONS. ANY DEVIATION FROM THESE PLANS WILL REQUIRE PRIOR APPROVAL FROM THE OWNER, THE CITY ENGINEER, AND OTHER APPROPRIATE PUBLIC AGENCIES.

2. ALL PIPE MATERIALS SHALL MEET THE REQUIREMENTS OF THE CITY STANDARDS AND SPECIFICATIONS. ACCEPTABLE STORM DRAINAGE PIPE MATERIALS INCLUDE CONCRETE, PVC, HDPE, AND DUCTILE IRON. CORRUGATED METAL PIPES (GALVANIZED ALUMINUM OR STEEL) ARE NOT ACCEPTED BY THE CITY. ALL PIPE JOINTS MUST HAVE GASKETS AND SHALL BE WATER TIGHT UNLESS OTHERWISE DIRECTED BY THE CITY.

3. PIPE BEDDING MATERIAL SHALL BE 5/8-INCH MINUS CRUSHED GRAVEL FOR ALL PIPE TYPES, EXCEPT DUCTILE IRON. BEDDING MATERIAL FOR DUCTILE IRON PIPE SHALL MEET THE REQUIREMENTS OF THE CITY'S STANDARDS AND SPECIFICATIONS (CHAPTER 4).

4. ALL TRENCH BACKFILL IN AREAS OF PAVEMENT OR STRUCTURAL LOADING SHALL BE COMPACTED TO AT LEAST 95% OF THE MAXIMUM DRY DENSITY. ALL OTHER AREAS SHALL BE COMPACTED TO AT LEAST 90% OF MAXIMUM DRY DENSITY.

5. ALL PIPE SHALL BE PLACED ON STABLE EARTH. IF IN THE OPINION OF THE CITY INSPECTOR, THE EXISTING TRENCH FOUNDATION IS UNSATISFACTORY, THEN IT SHALL BE EXCAVATED BELOW GRADE AND BACKFILLED WITH GRAVEL BEDDING MATERIAL TO SUPPORT THE PIPE.

6. LOT DRAINAGE SYSTEMS, STUB-OUTS AND ANY DRAINS BEHIND THE SIDEWALK MUST BE INSTALLED AS REQUIRED PRIOR TO SIDEWALK CONSTRUCTION. STUB-OUTS SHALL BE MARKED WITH A 2"X4" WITH 3 FEET VISIBLE ABOVE GRADE AND MARKED "STORM". LOCATION AND DEPTH OF THESE INSTALLATIONS SHALL BE SHOWN ON THE AS-BUILT PLANS SUBMITTED TO THE CITY.

6. ALL CATCH BASINS SHALL BE TYPE 1 UNLESS OTHERWISE SHOWN ON THE PLANS AND APPROVED BY THE CITY. THE USE AND INSTALLATION OF INLETS IS DISCOURAGED.

7. ALL CATCH BASINS WITH A DEPTH OF 5 FEET (RIM TO INVERT) OR GREATER SHALL BE TYPE 2 CATCH BASINS EQUIPPED WITH 3/4-

INCH DIAMETER SAFETY MANHOLE STEPS OR A MANHOLE LADDER PER CITY STANDARD DETAILS.

8. ALL GRATES SHALL BE MARKED "OUTFALL TO STREAM - DUMP NO POLLUTANTS". ALL SOLID COVER SHALL BE MARKED "DRAIN". ALL CATCH BASINS AND MANHOLES SHALL BE EQUIPPED WITH LOCKING FRAMES AND LIDS OR GRATES PER CITY STANDARD DETAILS.

9. ALL GRATES LOCATED IN THE GUTTER FLOW LINE (INLET AND CATCH BASIN) SHALL BE DEPRESSED 0.1 FOOT BELOW PAVEMENT LEVEL.

10. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ADJUSTING ALL MANHOLE, INLET AND CATCH BASIN FRAMES AND GRATES/COVERS TO GRADE JUST PRIOR TO CURB INSTALLATION AND/PAVING.

11. ALL RETENTION/DETENTION FACILITIES SHALL BE INSTALLED AND IN OPERATION PRIOR TO, OR IN CONJUNCTION WITH, ALL CONSTRUCTION ACTIVITY, UNLESS OTHERWISE APPROVED BY THE CITY.

12. DETENTION/RETENTION PONDS WITH SIDE SLOPES STEEPER THAN 3:1 OR WITH A MAXIMUM WATER DEPTH GREATER THAN 3 FEET SHALL BE ENCLOSED WITH A VINYL COATED CHAIN LINK FENCE.

12. BIO-FILTRATION SWALES AND/OR FILTER STRIPS SHALL BE CONSTRUCTED, BEDDED OR SEEDED AND IN OPERATION PRIOR TO, OR SODDED IN CONJUNCTION WITH, ASPHALT PAVING. THE VEGETATION IN THE BIO-SWALE MUST BE WELL ESTABLISHED BEFORE PAVING BEGINS.

13. STORM WATER RETENTION/DETENTION FACILITIES, STORM DRAINAGE PIPE AND CATCH BASINS SHALL BE FLUSHED AND CLEANED BY THE DEVELOPER PRIOR TO THE CITY'S ACCEPTANCE OF THE PROJECT.

14. WHEN INFILTRATION FACILITIES ARE CONSTRUCTED, COMPACTION OF SOIL IS NOT ALLOWED, AS THE DESIGN IS BASED ON NATURAL SOIL IN THE ORIGINAL LOCATION. VEHICLES SHALL NOT BE DRIVEN OVER THE INFILTRATION AREA DURING CONSTRUCTION.

15. IF THE CONTRACTOR ENCOUNTERS GROUNDWATER OR SOIL CONDITIONS DIFFERENT FROM THAT SHOWN IN THE PLANS DURING INFILTRATION SYSTEM INSTALLATION, THE CONTRACTOR SHALL NOTIFY THE CITY INSPECTOR.