

CITY OF ARLINGTON
SEWER SYSTEM CONSTRUCTION NOTES:

1. ALL WORK SHALL BE IN ACCORDANCE WITH THE APPROVED PLANS, AND CURRENT EDITION OF THE CITY OF ARLINGTON STANDARDS AND SPECIFICATIONS. ANY CHANGES TO THE DESIGN REQUIRES CITY APPROVAL.

2. ALL MATERIALS SHALL CONFORM TO THE CITY OF ARLINGTON STANDARDS AND SPECIFICATIONS AND THE MATERIAL SUBMITTALS SHALL BE APPROVED BY THE CITY BEFORE SCHEDULING THE PRECONSTRUCTION CONFERENCE AND BEFORE THE MATERIALS ARE DELIVERED TO THE JOB SITE. ONCE THE MATERIALS ARE DELIVERED TO THE JOB SITE THE INSPECTOR WILL DETERMINE IF THE MATERIALS WERE MANUFACTURED TO MEET THE REQUIREMENTS OF THE CITY OF ARLINGTON STANDARDS AND SPECIFICATIONS BEFORE THE MATERIALS CAN BE INSTALLED.

3. ALL SEWER MAINS AND SIDE SEWER STUBS SHALL BE FIELD STAKED FOR GRADES AND ALIGNMENT BY A SURVEYOR PRIOR TO CONSTRUCTION. THE CONSTRUCTION STAKES MUST SHOW THE STATION AND OFFSET TO THE ALIGNMENT.

4. THE CITY OF ARLINGTON WASTEWATER DIVISION SHALL BE NOTIFIED A MINIMUM OF 48 HOURS IN ADVANCE OF A TAP OR CONNECTION TO AN EXISTING SANITARY SEWER MAIN. THE INSPECTOR SHALL BE PRESENT AT THE TIME OF THE TAP OR CONNECTION.

5. GRAVITY SEWERS, INCLUDING SIDE SEWERS, WITH 5 TO 14 FEET OF COVER SHALL BE PVC ASTM D 3034 SDR 35. GRAVITY SEWER MAINS WITH LESS THAN 5 FEET OR GREATER THAN 14 FEET OF COVER SHALL BE DUCTILE IRON PIPE CLASS 52, OR C-900 PVC. IF DUCTILE IRON PIPE IS USED FOR SEWER, THE PIPE INTERIOR SHALL BE EPOXY COATED (NOT CEMENT-LINED).

6. PRE-CAST MANHOLES SHALL MEET THE REQUIREMENTS OF ASTM C-478. JOINTS SHALL BE RUBBER GASKETED AND GROUTED BOTH INSIDE AND OUTSIDE OF THE MANHOLE PER CITY OF ARLINGTON STANDARDS AND SPECIFICATIONS. ALL LIFT HOLES CUT THROUGH THE WALLS OF THE MANHOLE SHALL BE GROUTED FROM THE INSIDE AND OUTSIDE OF THE MANHOLE TO BE WATERTIGHT. ADDITIONAL WATERPROOFING MAY BE REQUIRED.

7. SIDE SEWER SERVICES SHALL BE PVC ASTM D 3034 SDR 35 WITH FLEXIBLE GASKETED JOINTS. SIDE SEWER CONNECTIONS SHALL BE MADE BY A TAP TO AN EXISTING MAIN OR A TEE FROM A NEW MAIN

CONNECTED ABOVE THE SPRING LINE OF THE PIPE. WYES ARE NOT ALLOWED ON LINES 8" OR LARGER. SIDE SEWERS CAN NOT BE INSTALLED UNDER DRIVEWAYS UNLESS APPROVED BY THE CITY INSPECTOR.

8. ALL SEWER PIPE SHALL BE INSTALLED WITH A CONTINUOUS TRACER TAPE 24" - 48" UNDER THE PROPOSED FINISHED SUBGRADE, OR AS DIRECTED BY THE CITY INSPECTOR. THE MARKER SHALL BE PLASTIC, NON-BIODEGRADABLE, METAL CORE, AND DETECTABLE, WITH BACKING MARKED "SEWER".

9. SIDE SEWERS SHALL BE INSTALLED BY THE DEVELOPER AND COORDINATED FOR CLEARANCE WITH POWER, GAS, TELEPHONE, CABLE, AND OTHER UTILITIES. SIDE SEWERS SHALL BE A MINIMUM OF 10 FEET BEYOND PROPERTY LINES AND 5' BEYOND ANY EASEMENT.

10. THE SEWER PIPE SHALL BE INSTALLED STARTING FROM DOWNSTREAM OF THE POINT OF CONNECTION ON THE EXISTING SEWER OR FROM A DESIGNATED STARTING POINT. THE SEWER PIPE SHALL BE INSTALLED WITH THE BELL END UPSTREAM.

11. ADEQUATE TRENCH SHEETING AND/OR SHORING SHALL BE PROVIDED BY THE CONTRACTOR AS REQUIRED BY OSHA AND WISHA.

12. TO PREVENT WATER OR DEBRIS FROM DISCHARGING INTO THE CITY'S EXISTING SEWER SYSTEM, THE CONTRACTOR SHALL INSTALL A PLUG IN THE CONNECTION MANHOLE OR AS DIRECTED BY THE CITY INSPECTOR. THE PLUG SHALL NOT BE REMOVED UNTIL THE SEWER IS ACCEPTED BY THE CITY.

13. ALL SEWER LINES SHALL MAINTAIN A MINIMUM OF 10 FEET HORIZONTAL CLEARANCE AND A MINIMUM OF 18 INCHES VERTICAL CLEARANCE FROM WATER LINES. SEE STANDARDS AND SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS AND ALTERNATIVES.

14. PIPE BEDDING SHALL BE IN ACCORDANCE WITH THE CITY OF ARLINGTON STANDARD AND WSDOT STANDARD SPECIFICATIONS. 3/8-INCH MINUS MANUFACTURED CLEAN PEA GRAVEL IS THE REQUIRED BEDDING MATERIAL. ALL PIPE SHALL BE LAID ON A PROPERLY PREPARED FOUNDATION. THIS SHALL INCLUDE NECESSARY LEVELING OF THE TRENCH BOTTOM OR THE TOP OF THE FOUNDATION MATERIALS AS WELL AS PLACEMENT AND COMPACTION OF REQUIRED BEDDING MATERIAL TO UNIFORM GRADE SO THAT THE ENTIRE LENGTH OF THE PIPE WILL BE SUPPORTED BY A UNIFORMLY DENSE UNYIELDING BASE.

15. THE CONTRACTOR SHALL COMPACT TRENCH BACKFILL WITHIN THE CITY RIGHT-OF-WAY TO AT LEAST 90% MAXIMUM DRY DENSITY FROM THE BOTTOM OF THE TRENCH TO A DEPTH OF 3' BELOW THE SURFACE. THE TRENCH BACKFILL MUST BE COMPACTED TO AT LEAST 95% MAXIMUM DENSITY WITHIN 3' OF THE SURFACE. ASPHALT MUST BE COMPACTED TO MEET THE REQUIREMENTS ON THE PLANS. ALL COMPACTION TESTS ARE AT THE DEVELOPER'S EXPENSE.