

**CITY OF ARLINGTON**  
**WATER SYSTEM CONSTRUCTION NOTES:**

1. ALL WORK SHALL BE IN ACCORDANCE WITH THE APPROVED PLANS AND CURRENT EDITION OF THE CITY OF ARLINGTON STANDARDS AND SPECIFICATIONS. ANY CHANGES TO THE DESIGN REQUIRE CITY APPROVAL.
2. ALL MATERIALS SHALL CONFORM TO THE CITY STANDARDS AND SPECIFICATIONS AND SHALL BE APPROVED BY THE CITY PRIOR TO DELIVERY TO THE JOB SITE. MATERIAL SUBMITTALS ARE REQUIRED AND MUST BE APPROVED PRIOR TO SCHEDULING A PRE-CONSTRUCTION CONFERENCE.
3. WATER MAINS SHALL BE CEMENT-LINED DUCTILE IRON PIPE CLASS 52 UNLESS OTHERWISE APPROVED BY THE CITY.
4. ALL SERVICE LOCATIONS SHALL BE FIELD APPROVED BY THE CITY PRIOR TO INSTALLATION.
5. IT IS THE CONTRACTOR'S RESPONSIBILITY TO LOCATE UNDERGROUND UTILITIES BY CALLING ONE-CALL UNDERGROUND UTILITY LOCATOR (1-800-424-5555) 48 HOURS PRIOR TO CONSTRUCTION.
6. ADEQUATE TRENCH SHEETING AND/OR SHORING SHALL BE PROVIDED BY THE CONTRACTOR AS REQUIRED BY OSHA AND WISHA.
7. THE PIPE SHALL BE INSTALLED BY FOLLOWING THE FINISHED GRADE PROFILE WHEREVER POSSIBLE. THE DEPTH OF COVER SHALL BE TYPICALLY 36 INCHES (3 FEET), AND MAY BE UP TO 60 INCHES (5 FEET) WITH THE APPROVAL OF THE CITY ENGINEER. WATER MAINS UNDER THE STATE (OR COUNTY) HIGHWAYS SHALL MEET THE MINIMUM COVER DEPTHS REQUIRED BY WSDOT (OR SNOHOMISH COUNTY).
8. PIPE JOINT DEFLECTIONS SHALL NOT EXCEED ONE-HALF OF PIPE MANUFACTURER'S RECOMMENDED MAXIMUM DEFLECTIONS. BENDS MAY BE REQUIRED TO MAINTAIN PROPER WATER MAIN ALIGNMENT WITHIN EASEMENTS OR PUBLIC RIGHT-OF-WAY.
9. WATER MAIN SHALL NOT BE PLACED UNDER SIDEWALK, CURBS, GUTTERS, OR ANY PERMANENT STRUCTURES WITHOUT THE PRIOR APPROVAL OF THE CITY ENGINEER.
10. NO CONNECTION TO THE CITY WATER SYSTEM IS ALLOWED UNTIL THE NEW CONSTRUCTION PASSES PRESSURE AND PURITY TESTS, AND

HAS BEEN APPROVED AND ACCEPTED BY THE CITY.

11. PRIOR TO MAKING CONNECTIONS TO THE EXISTING SYSTEM, CONTRACTOR SHALL FIELD VERIFY THE LOCATION, DEPTH AND MATERIAL OF EXISTING WATER MAINS AT THE POINT OF CONNECTION.

12. ALL WATER LINES SHALL BE A MINIMUM OF 10 FEET HORIZONTAL CLEARANCE FROM SANITARY SEWERS. WHEN WATER LINES CROSS SEWER LINES, THE MINIMUM VERTICAL CLEARANCE SHALL BE 18 INCHES.

13. TO FILL THE MAIN FOR FLUSHING, PRESSURE AND PURITY TESTS, THE CONTRACTOR IS REQUIRED TO USE AN APPROVED METER AND DCVA. THE HYDRANT SHALL REMAIN IN THE FULL OPEN POSITION TO PREVENT BACK-SIPHONAGE THROUGH THE DRAIN HOLE. AFTER SUCCESSFUL TESTING, THE CONTRACTOR WILL TIE INTO THE EXISTING SYSTEM, USING DISINFECTED SLEEVES AND SPOOL PIECES.

14. THE CONTRACTOR SHALL CONTACT THE CITY FOR VALVE OPERATION. ONLY AUTHORIZED REPRESENTATIVES OF THE CITY CAN OPERATE VALVES IN THE CITY WATER SYSTEM.

15. THE CONTRACTOR IS HEREBY NOTIFIED THAT, SINCE FILLING AND FLUSHING WILL BE DONE THROUGH A CROSS-CONNECTION CONTROL DEVICE, LOW VELOCITY FLOWS MAY BE ENCOUNTERED. THEREFORE, EVERY ATTEMPT SHALL BE MADE TO KEEP THE PIPE CLEAN DURING INSTALLATION. THIS MAY INCLUDE SWABBING THE PIPE WITH CHLORINATED WATER.

16. THE CONTRACTOR SHALL PERFORM TEMPORARY SOIL EROSION AND SEDIMENTATION CONTROL, DUST CONTROL, NOISE CONTROL, AND TRAFFIC CONTROL AS REQUIRED BY THE CITY OR OTHER APPLICABLE AGENCIES.

17. CUTTING AND PATCHING OF ROAD WAYS SHALL CONFORM TO THE REQUIREMENTS OF THE RIGHT-OF-WAY PERMIT OF THE CITY OR OTHER APPLICABLE AGENCY.

18. ALL IN-LINE PIPE JOINTS SHALL BE RESTRAINED WITH FIELD LOCK GASKETS.

19. ALL FITTINGS SHALL BE RESTRAINED JOINTS AND HAVE THRUST BLOCKING.